



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES

1875 New Hope Street
Norristown, PA 19401
215 270-1975

September 20, 1990

Mr. David R. Haldeman
Environmental Specialist
~~Scott Paper Company~~
Front and Avenue of the States
Chester, PA 19013

Re: UST Closure
Scott Paper Company
City of Chester
Delaware County

Dear Mr. Haldeman:

We have reviewed the data submitted May 23, 1990 concerning the proposed closure of a 20,000 gallon underground storage tank which stored No. 6 fuel oil but could not be removed due to its location. The proposal is deficient because only one groundwater monitoring well was installed and sampled. Our guidance document for underground storage tank closure requires at least three borings/wells with both soil and groundwater samples collected. All results should be compared to background concentrations of total petroleum hydrocarbons.

Please submit a proper site assessment to this office by October 30, 1990.

If you have any questions, please call me at 270-1975.

Very truly yours,

Richard Breitenstein

RICHARD K. BREITENSTEIN
Water Quality Specialist

cc: City of Chester
Ms. Perry
Ms. Kinkaid
Re 30 (1)263.3